



Scienta Envinet

MIRA

Gross gamma detection system



# MIRA

Gamma dose rate monitoring system



## Gamma dose rate monitoring system

- Gamma dose rate measurement with temperature-compensated GM tubes
- For mobile as well as fixed applications
- Extra wide dose rate range: 10 nSv/h – 10 Sv/h
  
- No infrastructure required
  - Extremely low power consumption
  - Battery and / or solar operation
  - Bi-directional, redundant wireless data communication
  - Compact design
- >10 years non-volatile memory, data synchronisation with network centre





## Measurement

### Two Geiger-Müller Tubes, LD + HD:

- Temperature and background compensated
- Deadtime correction
- Automatic switching between LD- and HD channel with overlap
- Detection range from 10 nSv/h – 10 Sv/h
- Individual calibration with certificate





## All functionality on board

### Full set of functions

- Base measurement interval 1min with three configurable aggregations
- Spontaneous calls on anomalous events
- Automatic switching to intensive mode
  
- 40+ technical and 10+ radiological statuses
- Internal health watchdog
  
- Automatic integrated accuracy test with detector health check and Android app



## Robust design



### **Self-contained device for all conditions**

- Optimized glass fibre housing for minimal gamma absorption and highest environmental resistance
- IP68 detector compartment, resistant to water, dust, sand and salt
- No maintenance required
  
- Operation range: -40°C – 60°C
- Wind resistance beyond 120 km/h
  
- GPS sensor for localization
- Optional binary rain sensor

## Lowest power consumption

### Fully autonomous operation

- 10mW power consumption
- Internal and external solar panel available
- Up to 40 days operation using the internal battery
- Battery exchangeable by user
- IP65 battery compartment
- 5V DC (USB)



## Communication ready!

### Manifold communication options:

- Built-in: LAN, RS 485, LTE/3G/2G (antennas inside)
- Service: RS 232, Bluetooth
- In cabinet: Iridium satellite, RF radio, LoRa WAN
- Bi-directional TCP/IP communication, compressed binary
- Secure TLS/SSL data transfer, APN
- Up to 5 monitoring centres
- Full support in NMC










## Perfectly integrated with NMC

### The network centre, local and in the cloud:

- Time series plots and analysis
- Reporting and data-sharing functionality
  
- Alarm management
- GIS integration
  
- Secure communication and remote configuration
- Consolidation of communication channels



Variants available (examples):

Gamma Detector	Fixed Monitoring Station	Autonomous Station	Mobile Station
 <ul style="list-style-type: none"> <li>• Flexible application</li> </ul>	 <ul style="list-style-type: none"> <li>• Remote application</li> </ul>	 <ul style="list-style-type: none"> <li>• Various applications</li> </ul>	 <ul style="list-style-type: none"> <li>• Mobile use, with GPS</li> </ul>
<b>CONFIGURED TO YOUR NEEDS</b>			
	<ul style="list-style-type: none"> <li>• LAN, LTE, RS-485 etc.</li> </ul>	<ul style="list-style-type: none"> <li>• battery buffer</li> <li>• Wireless communication, LTE and satellite</li> </ul>	<ul style="list-style-type: none"> <li>• Wireless communication</li> <li>• Quickly deployable</li> </ul>

## A selection of useful accessories

### Test set


- For recurring automatic accuracy test
- Cs-137, ~360 kBq or Eu-152, ~500 kBq
- Including carrying case



### Vaisala weather station

- High quality weather data
- Precipitation, humidity, temperature, wind speed and direction, pressure
- Low power consumption
- Perfect addendum for measurement plausibility checks and GDR prediction







This project is funded by the European Union.


# MIRA

Components and supply







Binder type



Fischer type






## Main features

- Supply via mains and/or solar
- UPS functionality (supports Li and Pb batteries)
- Overvoltage protection
- 12 VDC and 5 VDC supply voltages
  
- “Door open” and “battery low” signal
- Power status LEDs
  
- Unique interface to MIRA and SARA
- Access to serial console via USB
- LAN interface
- Serial interfaces to external devices  
(radio or satellite modems, weather transmitter etc)
  
- External display *(option)*





- incl. stack with  
Hydra BB – EnviNeck - UARTNeck
- required for  
2 or more serial devices to be connected



PE

Battery

Solar panel

Mains supply  
5 ... 25 VDC

ON/OFF  
external supply

*Batt voltage present*

*Batt voltage good*


*Solar supply present*

*Mains supply present*

Battery voltage must be < 15 VDC for LED signaling



Diese Zeichnung ist unser Eigentum. Vervielfältigung, unbefugte Verwendung, Mitteilung an andere ist strafbar.  
 © ENVINET GmbH




# MIRA

Measuring gamma dose rate




### Detection of ionizing particles with Geiger-Müller-Tubes




inert counting gas (Ne)  
+  
quenching gas (halogen)


**Result: counts per minute (cpm) ~ intensity of gamma radiation field**  
( $\alpha$ ,  $\beta$  absorbed)



- Detection range 10 nSv/h ... 10 Sv/h
- Accuracy  $\pm 15\%$
- Calibrated energy range 38 keV ... 1.3 MeV (3 MeV)
- Temperature compensation  $< 1\%$  per  $10^\circ\text{C}$
- Sensitivity LD 809.5 cpm /  $\mu\text{Sv/h}$  (max 300,000 cpm)  
HD 0.9404 cpm /  $\mu\text{Sv/h}$  (max 3,000,000cpm)
- LD intrinsic background compensated
- Operating temperature  $-40^\circ \dots +60^\circ\text{C}$



Spitze zeigt Richtung Decke/Beschriftung zeigt Richtung Quelle (auf Dreibein aus Plastik montiert) bei 0 Grad





# MIRA

Options and extensions



## Vaisala WXT530 Series

### ■ Measure parameter options

- Precipitation 0 ... 200 mm/h @  $< \pm 5\%$
- Wind speed and direction 0 ... 60 m/s @  $\pm 3\%$  / 0 ... 360° @  $\pm 3^\circ$
- Pressure 600 ... 1100 hPa @  $\pm 1$  hPa
- Temperature -52 ... +60°C @  $\pm 0.3^\circ\text{C}$
- Relative Humidity 0 ... 100 %rH @  $\pm 3/5$  %rH

### ■ Connection via serial interface

### ■ Low power consumption (42 mW)

### ■ Full integration

- Part of MIRA measure value ensembles
- Display as data series in NMC



## Iridium Edge



### NETWORK

- ▶ Frequency: 1616 – 1626.5 MHz
- ▶ Message Size: 270 bytes (Receive), 340 bytes (Transmit)
- ▶ SBD Transceiver: Iridium 9602N
- ▶ Antenna: Integrated Iridium® certified antenna



### ENVIRONMENTAL

- ▶ Operating Temperature Range: -40C to 85C
- ▶ Storage Temperature Range: -40C to 85C
- ▶ Vibration: SAE J1455, Section 4.10



### MECHANICAL

- ▶ Dimensions: 130 mm (L) x 80 mm (W) x 30 mm (H)
- ▶ Ingress Protection: IP 67
- ▶ Side and Bottom Cable Exits
- ▶ Connector: M12-8 pin male, terminated on 20cm pigtail cable
- ▶ Installation Options: Pole, Screw, Tape



### CERTIFICATIONS

- ▶ Iridium® Satellite Network Certification
- ▶ RoHS Compliant
- ▶ FCC, IC, CE, Australia Approvals



### POWER

- ▶ Power Supply: ( 9-32V), SAE J1455 Load Dump Protected
- ▶ Maximum Power: 1.6W ( Peak for Short Transmit Burst)
- ▶ Low Power Modes: < 200uA
- ▶ Reverse Polarity Protection



### INTERFACES

- ▶ RS232 AT Command Interface
- ▶ On/Off Control Lines

# MIRA


Data evaluation



Energy compensation / no discrimination between gamma energies



Calibration with reference to **Cs-137 (662 keV)** source up to 10 Sv/h  
at standard laboratory HZM (Helmholtz-Zentrum München)



## Periodic self-test

- Probe enters state 0 (LD/HD on, high sampling freq.)
  
- Raw pulse rates from LD and HD used to check detector functionality:
  - Minimum criteria ( $\sum_{t_{min}} n_i > n_{min}$  for each channel)
  
  - Pulse rate correction after clock synchronization
  
  - Comparison LD – HD channel
  
  - Pulse rate drift

Evaluated pulse rate  $n$   
 10 sec base interval (*default*)  
 correct interval for time synchronisation



Calculate uncorrected dose rate  $D_0$

$$D_0 = \frac{n}{e \cdot (1 - n \cdot \tau)}$$

dead time algorithm



line approximation

$$D_0 = \frac{n - b}{k}$$

$e$  Sensitivity  
 $\tau$  Dead time

Calculate corrected dose rate

- subtract temperature compensation  $D_r = \frac{1}{e} \left( p_1 + \frac{1 + p_2(T + p_3)^2}{1 + p_4 \cdot T} \right)$
- subtract intrinsic effect ( $\sim 30 \dots 40 \text{ nSv/h}$ )
- subtract location correction factor (*configurable; default =0*)
- plausibility of readings in succeeding intervals (*disabled*)



Sum up aggregated values

System time: UTC

Options for real time synchronization

- SNTP triggered by NMC server (on  $\Delta t > 2$  sec; adjustable)  
→ access to NTP server required
- NMC server time
- GPS time (mobile stations; on request)


Data aggregation and buffering

- Configurable basic measure interval  
(default: 1 min)
- 3 configurable aggregation ensembles  
(default: 10 min, 1h, 1d)
- Permanent data storage during the probe's live time  
(up to 1 GB SD card)



Poisson distribution: Standard deviation  $\sigma = \sqrt{n}$  (68%(2 $\sigma$ : 95%) of all measurements)  
 Standard error  $1/\sqrt{n}$

Example: 81 nSv / h background  $\rightarrow$  ~ 67 cpm



81 nSv/h mean value

1 min: 2 $\sigma$  = 24% i.e.  $\pm$  20 nSv/h  
 10 min: 2 $\sigma$  = 7.7% i.e.  $\pm$  6.3 nSv/h  
 1 h: 2 $\sigma$  = 3.2% i.e.  $\pm$  2.6 nSv/h

- Secondary cosmic component

GM detectors and HPIC: overestimation due to increasing sensitivity above 1.3 MeV  
 NaI / LaBr Scintillators: underestimation due to cutoff at 3 MeV


- Terrestrial component

Difference IGS421/AGS421/MIRA ↔ IGS711 ± 2 nSv/h  
 (measured in mining plant)

- Intrinsic effect

MIRA 30 ... 40 nSv/h (*K-40*)  
 SARA NaI(Tl) 2 ... 4 nSv/h  
 SARA LaBr 100 nSv/h (*La-138*)  
 (measured in Pb chamber)

➤ Offset setting for the background reading alignment




reference: BFS


# MIRA

System architecture and data transmission





- TCP/IP socket connection to NMC-Server
- TCP/IP port 31000
- Station ID for identification @ NMC
- Binary protocol basing on Google Protocol Buffers including messages for
  - Data transfer
  - Station status queries
  - Configuration
  - Firmware updates
  - Time synchronisation



- 5 data server (= monitoring center) configurable  
+ update server & service
- IP address + port selectable (default: port 31000)
- 4 comm devices per server configurable (fall back mechanism)
- Standard protocol („protocol buffers“)
- Encryption TLS 1.3 available
- TCP/IP based (i.e., additional services like NTP for time sync available)
- Control of communication schedule by NMC
  - Intensive mode data call cycle
  - Comm alarm in case of missing scheduled MIRA call
  - Report comm statistics and next expected data call (monitor)
- Permanent availability (comm device ON) as option

## ■ LAN

- Local networks
- Parallel processing of several MIRA calls
- External connection to router (GPRS/UMTS/LTE, WLAN, radio, ADSL, ...) serving infrastructure and security requirements (e.g. VPN, IPsec, IPv6, ...)

## ■ LTE

- Server with fixed public IP address
- Parallel processing of several MIRA calls

## ■ Radio

- external radio modem with antenna
- „Line of sight“ required (radio network design)
- Time slice method

## ■ Serial (RS232 / RS485 / Bluetooth)

- no addressing
- Time slice method
- no service console during normal measurement operation for RS232/BT

## ■ Satellite

- External satellite modem with antenna
- UDP “one shot”
- E-mail

### Scheduled data call



NMC Server



#### Time settings

**Normal Mode Schedule**

Start time: 18.07.2017 23:00

Cycle type:  Hourly  Daily

Interval: 0 h  1 min


---

**Intensive Mode Schedule**

Start time: 18.07.2017 23:00

Cycle type:  Hourly  Daily

Interval: 0 h  1 min




### Spontaneous call (event triggered)



NMC Server

#### CommCo

Host	IP	Port	State	Last Update	Last Error	Last Status
10.10.10.1	10.10.10.1	10000	OK	18.07.2017 23:00		OK
10.10.10.2	10.10.10.2	10000	OK	18.07.2017 23:00		OK
10.10.10.3	10.10.10.3	10000	OK	18.07.2017 23:00		OK
10.10.10.4	10.10.10.4	10000	OK	18.07.2017 23:00		OK
10.10.10.5	10.10.10.5	10000	OK	18.07.2017 23:00		OK
10.10.10.6	10.10.10.6	10000	OK	18.07.2017 23:00		OK
10.10.10.7	10.10.10.7	10000	OK	18.07.2017 23:00		OK
10.10.10.8	10.10.10.8	10000	OK	18.07.2017 23:00		OK
10.10.10.9	10.10.10.9	10000	OK	18.07.2017 23:00		OK
10.10.10.10	10.10.10.10	10000	OK	18.07.2017 23:00		OK
10.10.10.11	10.10.10.11	10000	OK	18.07.2017 23:00		OK
10.10.10.12	10.10.10.12	10000	OK	18.07.2017 23:00		OK
10.10.10.13	10.10.10.13	10000	OK	18.07.2017 23:00		OK
10.10.10.14	10.10.10.14	10000	OK	18.07.2017 23:00		OK
10.10.10.15	10.10.10.15	10000	OK	18.07.2017 23:00		OK
10.10.10.16	10.10.10.16	10000	OK	18.07.2017 23:00		OK
10.10.10.17	10.10.10.17	10000	OK	18.07.2017 23:00		OK
10.10.10.18	10.10.10.18	10000	OK	18.07.2017 23:00		OK
10.10.10.19	10.10.10.19	10000	OK	18.07.2017 23:00		OK
10.10.10.20	10.10.10.20	10000	OK	18.07.2017 23:00		OK



**Event**

- technical issue
- threshold exceeding
- start / reset



# MIRA

Data access and alarming



10.02.2022 17:45

Detailed Status	Current	Registered
<b>MIRA System Status</b>		
Firmware version	1.5.7_release_R913_3fe8da2d_k60_lte	-
Digital Board Version	3	-
Analog Board Version	3	-
System starting	0	0
Service mode	0	0
Test mode	0	0
Minute timeout	0	0
Source detected	0	0
Source removed	0	0
SD-Card failed	0	0
Wake up	0	0
Base interval invalid	0	0
Time invalid	0	0
Time synchronization	0	0
GPS fix failed	0	0
GPS fix available	0	0
Moisture detected	0	0
Door open	0	0
Time synchronization failed	0	0
Communication failed	0	0
2G fallback	0	0
Task timeout	0	0
Task critical	0	0
Continuous test mode	0	0
<b>MIRA Battery Status</b>		
Battery low	0	0
Battery serious	0	0
Battery critical	0	0

Spontaneous Calls

• System Status

• GDR Evaluation Status

• Battery Status

0x0008 6089 6 items selected

Byte 4

Byte 3

Byte 2

Byte 1

0x0333 07c0 11 items selected

Byte 4  |

Byte 3

Byte 2

Byte 1  HD Minimum Criteria  
 LD Minimum Criteria  
 Communication Error  
 HD LD Comparison Short Term

0x0000 0007

Byte 4

Byte 3

Byte 2

Byte 1

## Actual status

Station status  
at time of data transmission


## Registered status


Events occurred  
since last successful data transmission

## Alarm mask

enables events for  
spontaneous call

	Threshold exceeding					
Station status	0	1	1		0	0
Registered status	0	1	0		0	0





## NMC




- all transmitted data
- actual and historic status
- remote configuration
- Tables / graphs / maps

## Text based serial console / MIRA App

```


MIRA30153
23.07.2015 14:26:00 UTC T1(C) 27.5 gdr(us/N) imin 0.079
23.07.2015 14:26:00 UTC T1(C) 27.5 gdr(us/N) imin 0.079
23.07.2015 14:26:00 UTC T1(C) 27.5 gdr(us/N) imin 0.094
23.07.2015 14:26:00 UTC T1(C) 27.5 gdr(us/N) imin 0.085
23.07.2015 14:26:00 UTC T1(C) 27.5 gdr(us/N) imin 0.089
23.07.2015 14:26:00 UTC T1(C) 27.5 gdr(us/N) imin 0.089
23.07.2015 14:30:00 UTC T1(C) 27.5 gdr(us/N) imin 0.088 10min 0.079
MIRA 306 60 1429 860 4.412 27.00 -1.127 mm 0.000 1451.78 16.56 4.161 67
data received server 4 Active started since 23.07.2015 14:30:00
MIRA 30 Address 192.168.100.87/255.255.0
MIRA 30 Gateway Address 192.168.100.0
connection closing
connection IPID: connecting to 192.168.148.67:31001 connected.
connection IPID: socket closed.
connection communication successful
connection duration: 211 ms
connection communication finished after 7 sec
connection IPID: 23.07.2015 15:05:00 UTC
conn stopping current transmission
conn IPID: connection successful
conn IPID: current state device on: ethernet (top/ip)
23.07.2015 14:31:00 UTC T1(C) 27.5 gdr(us/N) imin 0.075
23.07.2015 14:31:00 UTC T1(C) 27.5 gdr(us/N) imin 0.084
23.07.2015 14:31:00 UTC T1(C) 27.5 gdr(us/N) imin 0.080
23.07.2015 14:31:00 UTC T1(C) 27.5 gdr(us/N) imin 0.076
23.07.2015 14:31:00 UTC T1(C) 27.5 gdr(us/N) imin 0.069
23.07.2015 14:31:00 UTC T1(C) 27.5 gdr(us/N) imin 0.076
23.07.2015 14:37:00 UTC T1(C) 27.5 gdr(us/N) imin 0.079
23.07.2015 14:37:00 UTC T1(C) 27.5 gdr(us/N) imin 0.079
23.07.2015 14:40:00 UTC T1(C) 27.5 gdr(us/N) imin 0.092 10min
MIRA 306 63 1429 862 4.412 27.00 -1.127 mm 0.000 1451.78 16.45 4.161 67
data received server 4 Active started since 23.07.2015 14:30:00
MIRA 30 Address 192.168.100.87/255.255.0
MIRA 30 Gateway Address 192.168.100.0
connection closing
connection IPID: connecting to 192.168.148.67:31001 connected.
connection IPID: socket closed.
connection communication successful
connection duration: 211 ms
connection communication finished after 7 sec
connection IPID: 23.07.2015 15:05:00 UTC
conn stopping current transmission
conn IPID: connection successful
conn IPID: current state device on: ethernet (top/ip)
23.07.2015 14:41:00 UTC T1(C) 27.0 gdr(us/N) imin 0.091
23.07.2015 14:41:00 UTC T1(C) 27.5 gdr(us/N) imin 0.060
23.07.2015 14:43:00 UTC T1(C) 27.0 gdr(us/N) imin 0.070
23.07.2015 14:43:00 UTC T1(C) 27.5 gdr(us/N) imin 0.084
23.07.2015 14:43:00 UTC T1(C) 27.0 gdr(us/N) imin 0.089
23.07.2015 14:43:00 UTC T1(C) 27.0 gdr(us/N) imin 0.084
23.07.2015 14:47:00 UTC T1(C) 27.0 gdr(us/N) imin 0.074
23.07.2015 14:47:00 UTC T1(C) 27.0 gdr(us/N) imin 0.084
23.07.2015 14:47:00 UTC T1(C) 27.0 gdr(us/N) imin 0.084
23.07.2015 14:47:00 UTC T1(C) 27.0 gdr(us/N) imin 0.087 10min
MIRA 306 60 1429 862 4.412 27.00 -1.127 mm 0.000 1451.78 16.45 4.161 67
data received server 4 Active started since 23.07.2015 14:30:00
MIRA 30 Address 192.168.100.87/255.255.0
MIRA 30 Gateway Address 192.168.100.0
connection closing
connection IPID: connecting to 192.168.148.67:31001 connected.
connection IPID: socket closed.
connection communication successful
connection duration: 211 ms
connection communication finished after 7 sec
connection IPID: 23.07.2015 15:05:00 UTC
conn stopping current transmission
conn IPID: connection successful
conn IPID: current state device on: ethernet (top/ip)
23.07.2015 14:51:00 UTC T1(C) 27.5 gdr(us/N) imin 0.084
23.07.2015 14:51:00 UTC T1(C) 27.5 gdr(us/N) imin 0.084
23.07.2015 14:53:00 UTC T1(C) 27.5 gdr(us/N) imin 0.080

```



- current values
- current status
- local configuration
- communication setup
- accuracy test

- Storage in relational data base
- Automatic operation with
  - scheduled data transfer
  - scheduled export
  - scheduled reporting
- Presentation
  - Graph
  - Table
  - Map
- Alarming functions (remote / local)
- Remote configuration
- Centralized network control
- Device management



**MIRA**

- System status
  - MIRA System Status Registered
  - MIRA Battery Status Registered
- Channel 10: Dose Rate H\*(10)
  - MIRA Evaluation Status Registered

**MIRA Evaluation Status Registered**


Name	Alarm							Custom message
Rain		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Time synchronization		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HD overflow		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HD minimum criterion	Technical	●	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
LD minimum criterion	Technical	●	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Communication error	Technical	●	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HD LD comparison short term	Technical	●	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
HD LD comparison long term	Technical	●	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Test source present	Blocker		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Test mode			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
1min values: 1. threshold exceeded	Radiological	●	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1min values: 1. threshold exceeded
1min values: 2. threshold exceeded	Radiological	●	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1min values: 2. threshold exceeded
10min values: 1. threshold exceeded	Radiological	●	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	10min values: 1. threshold exceeded

# MIRA

Power management



- Internal battery allows up to 40 days of operation
- Can be recharged by
  - Mains power (standard USB power adapter, supply )
  - Solar panel (integrated or external)
- Major power consumers
  - $\mu$ C
  - LTE modem
  - LAN interface
  - GPS receiver
- Backup time strongly depends on communication interval
- Sophisticated power management with  $\mu$ C and internal devices are powered on scheduled basis



UTC




# MIRA

Configuration and maintenance



### ■ Input with magnet

- Wake up (trigger 1x) / restart (trigger 2x)
- Switch on BT for service → Access with App
- Accuracy test (triggered by test source)



### ■ Output with buzzer

```
STIEFL
options:
1: load a:\FIRMWARE\Updater.sbf
2: load a:\FIRMWARE\Factory.sbf
3: load a:\FIRMWARE\Firmware.sbf
4: enter shell
5: enter updater
7: force reinstall
8: reload configuration
9: reset boot parameters
0: enter sleep mode

selected: 3
installed: 3
..4

sdcard: installed to a:
file: a:\FIRMWARE\Shell.sbf
.....
.....
version installed: 1.0.0

ENVINET  GmbH
Hans-Pinsel-Strasse 4
85540 Haar (Munich)
Germany
info@envinet.com
http://www.envinet.com

----- MIRA Firmware version 1.0.0 branch develop revision 383 hash cbc4
----- Mira Firmware initialization -----
Station Id: 30106
----- Mira basic device initialization -----
startup time: 06.03.2014 08:21:17 UTC
----- Mira basic initialization complete -----
----- Mira device initialization -----
----- Mira initialization complete -----
----- Mira Firmware loaded -----
shell init ...
ENVINET MIRA Shell (build: Mar  4 2014)
MIRA>
MIRA>
```

boot menu: choose option 4 to enter shell


shell prompt

```
STIEFL
options:
1: load a:\FIRMWARE\Updater.sbf
2: load a:\FIRMWARE\Factory.sbf
3: load a:\FIRMWARE\Firmware.sbf
4: enter shell
5: enter updater
7: force reinstall
8: reload configuration
9: reset boot parameters
0: enter sleep mode

selected: 3
installed: 3
..0
entering sleep mode...
```

## Input:

- Magnetic switch
- Serial console (RS232 / bluetooth)



Speed via BT: 115200 bd

## Output:

- Beeper
- Serial console (RS232 / bluetooth)

- Station ID
- Device Settings
  - LAN
  - LTE
  - Radio
  - GPS
- Communication settings
- Cyclic calls
- Spontaneous calls
  - GDR thresholds
  - Alarm conditions
- Time Servers
- Accuracy test settings
- Counter tube and probe characteristics

The screenshot displays the configuration interface for Parameters MIRA30792\_FATOM (30792). The top navigation bar includes tabs for System, Devices, GDR, Accuracy Test, and Communication. The Communication tab is active, showing settings for Connection Retries (0), Time Servers (Time Server 0 to 3), and Central Connection Information (Central 0). The Central Connection Information section includes options for Enable, Communication Time (Time Offset, Repeat Base, Repeat On Success, Repeat On Failure, Time Window Size), Spontaneous Calls (0x0028 6089, 7 items selected), and System Status (Byte 1 to 4).

Time Server	IP1	IP2	IP3	IP4
Time Server 0	192	53	103	108
Time Server 1	192	53	103	104
Time Server 2	192	53	103	103
Time Server 3	0	0	0	0

Setting	Value
Enable	<input checked="" type="checkbox"/>
Communication Time	
Time Offset	0 h, 0 min, 0 s
Repeat Base	0 h, 5 min, 0 s
Repeat On Success	2 h, 0 min, 0 s
Repeat On Failure	0 h, 30 min, 0 s
Time Window Size (disabled=0)	0 h, 0 min, 0 s
Spontaneous Calls	0x0028 6089, 7 items selected
System Status	
Byte 4	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Byte 3	<input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Byte 2	<input type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Byte 1	<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input checked="" type="checkbox"/>



NMC-Server

schedule parameter retrieval



Next scheduled data call

*retrieve complete parameter set*

review and modify  
schedule parameter transfer



*send changed parameters*

Next scheduled data call

store in flash memory



*retrieve newly stored parameters*






review changes




# MIRA

Accuracy test





- Standard sources
  - Eu-152 (500 kBq)
  - Cs-137 (360 kBq)
- Procedure
  1. Preconfiguration via NMC / App:
    - Source type and s/n (requires new reference measurement)
    - Location of accuracy test/reference measurement
    - Operator
    - Duration of accuracy test/reference measurement
    - Evaluation criteria
  2. Place test source → Start indicated by acoustic signal
  3. Accuracy test
    - Switch to test mode
    - Wait for stable measure value (basic interval)
    - LD and HD pulse rate collection for preconfigured duration
    - Observation via BT + App
  4. End test indicated by acoustic signal → remove test source
  5. Evaluation and protocol
  6. Retrieve protocol from NMC





## Configuration and viewing reports by means of NMC

**1** Configure...

**2** Apply configuration

**3** Perform test (on site)


**4** Get report(s)

**5** View reports

Export to CSV or PDF

	07.12.2021 10:51:40	09.12.2021 09:19:10
Gerätebeschreibung		
Sonden Id	30805	30805
Sondentype	MIRA-100-L4-B	MIRA-100-L4-B
Firmware	2.5.2_master_R747_5ce95c6f_k64	2.5.2_master_R747_5ce95c6f_k64
Globale Daten		
Typ	Genauigkeitstest	Genauigkeitstest
Report Index	6	7
Standort		
Operator		
Quellenbeschreibung		
Quellen Id	MW 927	MW 927
Testnuclid	Cs-137	Cs-137
Referenzmessung	LD	LD
Messzeit	07.12.2021 10:35:10	07.12.2021 10:35:10
Dauer	10min	10min
Gesamtpulse [counts]	9900	9900
Pulsrate [cpm]	990	990
Genauigkeitstest	LD	LD
Messzeit	07.12.2021 10:35:10	09.12.2021 09:19:10
Referenz-Offset	16min 30s	1d 22h 44min
Dauer	10min	10min
Gesamtpulse [counts]	970	9950
Pulsrate [cpm]	970 (-20)	995 (+5)
Erwartete Pulsrate [cpm]	990	990
Abweichung	2.1%	0.5%
Testergebnis	Bestanden	Bestanden

... using the MIRA APP (on site)





Customized solutions available!

info@envinet.com  
www.scientaenvinet.com

+49 (89) 45 66 57-0

